ELSEVIER

Contents lists available at SciVerse ScienceDirect

Renewable and Sustainable Energy Reviews

journal homepage: www.elsevier.com/locate/rser



Fuzzy thermoeconomic optimisation applied to a small waste water treatment plant

Wendell de Queiroz Lamas a,b,*

ARTICLE INFO

Article history: Received 16 May 2012 Received in revised form 3 November 2012 Accepted 5 November 2012 Available online 7 December 2012

Keywords: Exergetic production cost Fuzzy non-linear programming problem Thermodynamic modelling

ABSTRACT

This work proposes to use thermodynamic modelling, and fuzzy thermoeconomic to optimise the small waste water treatment plant work period concerning to sewage treatment and energy generation through products associated to it. Thermoeconomic optimisation is described as a fuzzy non-linear programming problem in those local criteria is multi-objective: maximum exergetic efficiency and minimal total cost rate. These objective functions and constraints for this non-linear programming problem can be structured and represented by fuzzy sets. Several simulations about real possibilities are done to search the best performance configuration for the small waste water treatment plant. Results deal to previous system optimisation that was a physical optimisation through a thermoeconomic analysis. Then, Pareto set for this one indicated that the system had been optimised previously and it is working with better configuration.

© 2012 Elsevier Ltd. All rights reserved.

Contents

| 1. | Introduction | 214 |
|------|---------------|-----|
| 2. | Methodology | 216 |
| 3. | Results | 216 |
| 4. | Conclusions | 217 |
| Ack | nowledgements | 218 |
| Refe | erences | 218 |

1. Introduction

A small waste water treatment plant (SWWTP) has several products associated to sewage treated in it. The small waste water treatment plant at Sao Paulo State University, campus of Guaratingueta, in its original design, has a fat box, three anaerobic reactors, one aerobic–anoxic reactor, a gas holder, a H₂S filter, an internal combustion engine, and three heat exchangers to warm sewage in anaerobic reactors, improving micro-organisms colony growing. Also are produced water for re-use, biofertilizer, and biogas, and is generated electrical power. These products are directly dependant of sewage amount that becomes from

 $\textit{E-mail addresses:} \ lamaswq@aol.com, \ wendell@feg.unesp.br$

administration building and cafeteria. Figs. 1–3 show the small waste water treatment plant and its components. Fig. 4 shows the process diagram with flows and fluids detached.

The waste water from administration and cafeteria buildings (Fig. 2) enters through primary solids filter. This preliminary treatment eliminates the rudest solids, such as fat blocks.

The waste water follows through three up-flow sludge blanket anaerobic bioreactors, which separate solid residues (sludge), biogas, and waste water (preliminary treatment) through a helical phase flow. In this stage, part of the sludge is removed and used as biofertilizer. Another part is maintained because micro-organisms present in there, predominantly of *Methanosaeta* gender [5], digest organic material present in sludge to produce biogas. In Fig. 4 is possible to see heat exchangers associated to each anaerobic bioreactor. This is to maintain internal temperature in 37 °C, which is ideal for the micro-organisms presented in there [5]. This biogas is transferred to a gas holder, where it is stored at an appropriated

^a Post-graduate Programme in Mechanical Engineering, Department of Mechanical Engineering, University of Taubate, Brazil

^b Department of Basic and Environmental Sciences, Engineering School at Lorena, University of Sao Paulo, Brazil

^{*} Corresponding author at: University of Taubate, Department of Mechanical Engineering, Rua Daniel Danelli, s/n, Jardim Morumbi, 12060-440 Taubate, SP, Brazil Tel./fax: +55 12 3622 4005.



Fig. 1. Small waste water treatment plant (back view) [1-4].



Fig. 2. Small waste water treatment plant (front view) [1-4]].



Fig. 3. Small waste water treatment plant (water wheel) [1-4].

pressure for engine feeding, responsible for the generation of sufficient power energy to maintain associated small energy systems such as a control room, illumination, a pump etc.

The waste water flows until a fourth bioreactor (aerobic-anoxic), where aerobic micro-organisms digest any organic material that was not digested by anaerobic organisms, besides transforming ammoniacal nitrogen in nitrate. Anoxic micro-organisms transform nitrate in gaseous nitrogen and remove part of phosphorous in sludge bacterial biomass form. At that stage, treated water falls on a water wheel and generates mechanical power as well as air for aerobic bacteria treatment. This reusable water may be used in green areas ferti-irrigation.

A sort of anaerobic and aerobic bioreactors characteristics were obtained by [5–9], such as typical values for low power value of urban residues, biomass, and biogas, waste water treatment condition in Brazil, comparison between different bioreactors types, power generation and biogas production features, among others.

Focus on alternative energy sources has provided new modelling techniques, more accuracy of generating systems, allowing for a more rigorous and clear technical–economical analysis. As an example exergoeconomic and thermoeconomic analysis models have been used as a powerful tool for energy systems optimisation. Exergetic production cost (EPC) is a new method developed for the analysis and optimisation design of thermal systems. The objective of this technique is the minimum (optimal) total operating costs of a plant assuming a constant rate of production and electrical power generation [1,3,4,10–15].

Thermoeconomics is today a powerful tool for studying and optimising an energy generation system. The application of this technique is important for the evaluation of utility costs as products or supplies of production plants, energy costs between process operations or of an energy transformation system. These costs may be applied in viability studies, in investment decisions, by comparing alternative techniques and operating conditions, in a cost-effective evaluation of the equipment during installation, in an exchange or expansion of an energy system [10,12,13,15].

Several works based on the development of methodologies to model and to optimise thermal energy systems have been analysed in order to obtain information about techniques used in these evaluations [16–38].

Development of models for thermoeconomic design and operation optimisation has also been evaluated. These models deal with thermoeconomic optimisation and the best way to obtain balance between exergy balance and energy production/generation costs [39–53].

Thermoeconomics has been presented in several works relating exergy balance analysis and costs minimisation. These works have played an important role for the establishment of basic fundamentals issues necessary for the development of the proposed methodology [54–70].

The waste water treatment has been considered as a viable generator of an alternative fuel, biogas, according to the sewage treated and techniques used [71–73]. Methane is the main component of biogas generated by anaerobic waste water treatment and it is about 21 times more harmful than carbonic dioxide as related to greenhouse effect [7]. The use of biogas is very interesting, mainly when associated to renewable energy generation concepts and environmental protection.

Artificial intelligence techniques have been used to help analysis, mainly based on decision making, i.e., genetic algorithm, neural networks, rough sets, fuzzy logic, and others.

Mazur [74] had presented a work that achieves to include an uncertainty into classic thermoeconomic analysis in order to find solutions that simultaneously satisfy thermodynamic and economic goals, where thermoeconomic optimisation had been considered as a




Fig. 4. Process diagram [1,3,4].

fuzzy non-linear programming problem where local criteria: maximum energy (exergy) efficiency and minimum total cost rate as well as different constraints in an ill-structured situation can be represented by fuzzy sets. Mazur [75] also had developed a new approach for thermoeconomic analysis of energy-transforming systems based on the sequential uncertainty account to make decisions that simultaneously meet thermodynamic and economic goals.

Toffolo and Lazzaretto [76] had suggested how to perform a multi-objective optimisation in order to find solutions that simultaneously satisfy exergetic and economic objectives. Also a multi-objective optimisation for design of a benchmark cogeneration system known as CGAM cogeneration system was performed by [77,78]. A multi-objective optimisation with self-adaptive algorithm was developed by [79]. Fuzzy logic features associated to multi-objective optimisation for decision making issues was evaluated by [80]. Evolutionary algorithm features was associated to multi-objective optimisation by [81].

Das and Dennis [82–85] had proposed methods for Pareto optimal points evaluation for general non-linear multi criteria optimisation problem, with multi-objective features.

This work is a step forward of [3,4], also connected to [1], and proposes to use thermodynamic modelling, and fuzzy thermoeconomic to optimise the small waste water treatment plant work period concerning to sewage treatment and energy generation through products associated to it.

2. Methodology

Thermoeconomic optimisation is described as a fuzzy nonlinear programming problem in those local criteria is multiobjective: maximum exergetic efficiency and minimal total cost rate. These objective functions and constraints for this non-linear programming problem can be structured and represented by fuzzy sets. Several simulations about real possibilities are done to search the best performance configuration for the small waste water treatment plant.

The original SWWTP design anticipate 70 m³ of sewage diary with a mass flow of 4.28 kg/s, which flows for three anaerobic bioreactors with the same capacity of sewage storage and treatment, but generating different fractions of nominal 24 Nm³/day of biogas (mass flow of 1.47 kg/s), which are transferred to system gas holder. This gas holder sends the biogas to a motor-generator set with nominal capacity of 5.5 kW for diesel and 4 kW for biogas, working 10 h a day, feeding control room and illumination system. There is a fourth bioreactor, aerobic, that treats waste water before its transferring to anoxic purification stage for a final treatment stage. Biofertilizer can be obtained from both anaerobic and aerobic bioreactors. This treated water can be used to fertiirrigation or heating, coming into heat exchanger with a mass flow of 2 kg/s at 25 °C, coming out with a mass flow of 85 kg/h (0.024 kg/s) at 60 $^{\circ}$ C. Dairy from 8 h to 18 h, the effluent demand varies for each hour, such as: 15%, 10%, 5%, 5%, 25%, 15%, 10%, 5%, 5% and 5%. These periods are related to classes' hours [86].

A sort of assumptions must be considered. There are a several values considered for evaluations: 22,000 kJ/km³ (28,500 kJ/kg) for biogas lower heating value (LHV), 1.005 kJ/kg K for air specific heat at constant pressure, 1.094 kJ/kg K for exhaust gases specific heat at constant pressure [11], 0.001003 m³/kg for water specific volume at 25 °C [87], and 1,316.6 kcal/kg (5,477.056 kJ/kg) for biofertilizer LHV based on food waste [88]. Biofertilizer is considered with 40% of humidity in this work [6].

3. Results

The first step is to measure \dot{m}_{tw} . It was done using a polypropylene beaker with a linear scale of 1.1 L as span and a chronometer to

watch time spent to fill 1 L. This procedure was repeated ten times then a simple media was calculated to establish a value representative of this mass flow, for both conditions mentioned, with about 15% of uncertainty, because values for equipments degree of accuracy.

After that, the value obtained was converted to the international system unit adopted. With these values, \dot{m}_{bg} and \dot{m}_{bf} are estimated according to [88].

The $\dot{W}_{G_{\rm max}}$ was established as maximum power generated by internal combustion engine converted to use biogas, tested for the same composition of SWWTP biogas (0.6% of O₂, 2.4% of N₂, 40% of CO₂, 54% of CH₄ and 3% of H₂S [2]) and measured with a wattmeter.

For $\dot{W}_{G_{\rm max}}$ is not need to buy power from public grid (\dot{W}_{net}). In the minimal case ($\dot{W}_G = 1.65 \ kW$), the same value is bought from power grid, according to conditions established previously.

The ex_{bg} and ex_{bf} are considered as their own LHV [87,88], and ex_{tw} and ex_{sewer} are evaluated through a CATT3 software [87].

Table 1 relates values measured and evaluated for energy self-sufficiency condition for SWWTP (column Max) and values established for a 50% of energy self-sufficiency condition, with 50% of energy demand purchased (column Min).

Based on an extended thermoeconomic model of cogeneration plant developed by [76] and modified by [74,75] with two criteria which need to be minimised, two new equations representative of the thermodynamic criterion ($K_{\rm th}$) as a deviation of the exergetic efficiency of the SWWTP from an ideal value (the non-dimensional closing error of the system exergy balance) and the economic criterion ($K_{\rm ec}$) as the total cost rate of operation (the running cost) are adapted for SWWTP costs, according to cost-based structure for SWWTP, Fig. 5, Eqs. (1) and (2).

$$K_{th}(X) = 1 - \frac{\dot{W}_{net} + \dot{m}_{tw}(ex_{tw} - ex_{sewer}) + \dot{m}_{bf}\left(ex_{bf} - ex_{sewer}\right) + \dot{W}_G}{\dot{m}_{bg}ex_{bg}}$$

$$K_{ec}(X) = \dot{C}_{hg} + \dot{C}_{el} + \dot{C}_{hf} + \dot{C}_{tw}$$
(2)

For (1) and (2), \dot{W}_{net} is a public electrical power grid, $\dot{m}_{tw(bf,bg)}$ is a treated water (biofertilizer, biogas) mass flow rate, $ex_{tw(bf,bg,sewer)}$ is a treated water (biofertilizer, biogas, and sewer) specific exergy, and \dot{W}_G is electrical power generated by the system.

For calculation of costs associated to SWWTP products some analysis conditions are established: interest rate of 4%, 8%, 12%,

Table 1Thermodynamic features for thermodynamic criterion evaluation.

| | Min | Max |
|------------------------|-------------|------------|
| \dot{m}_{bg} [kg/s] | 0.000837325 | 0.00167465 |
| \dot{m}_{tw} [kg/s] | 0.007199025 | 0.01439805 |
| \dot{m}_{bf} [kg/s] | 0.000001365 | 0.00000273 |
| \dot{W}_{net} [kW] | 1.65 | 0 |
| \dot{W}_G [kW] | 1.65 | 3.3 |
| ex_{bg} $[kJ/kg]$ | 28,500 | 28,500 |
| ex_{tw} [kJ/kg] | 104.8 | 104.8 |
| ex_{bf} $[kJ/kg]$ | 5,477.06 | 5,477.06 |
| ex_{sewer} $[kJ/kg]$ | 104.8 | 104.8 |



Fig. 5. Cost-based structure [1,3,4].

Table 2Economic criteria for basic conditions < none > . < /none >

| r (%py) | K_{ec}^{\min} | K_{ec}^{\max} |
|---------|-----------------|-----------------|
| 4 | 0.188 | 0.572 |
| 8 | 0.212 | 0.600 |
| 12 | 0.238 | 0.630 |
| 16 | 0.267 | 0.659 |

and 16% per year and payback periods of 2, 4, 6, 8, and 10 years [3,4]. From these conditions associated to values evaluated in previous analysis [3,4], economic criteria is calculated, such as related in Table 2.

These values (Table 2) are applied to matrix table [T] to obtain boundary conditions for economic criteria evaluation.

The definition of the decision variable X (x_1 =sewer), physical constraints, and the purchase cost functions for each plant component are taken from work of Lamas et al. [1–4,86].

Fuzzification of the goals leads to the following membership functions:

$$\mu_{K_{th}}(X) = \begin{cases} 0, & \text{if} \quad K_{th}(X) > K_{th}^{\max} \\ \frac{K_{th}^{\max} - K_{th}(X)}{K_{th}^{\max} - K_{th}^{\min}} & \text{if} \quad K_{th}^{\min} < K_{th}(X) \le K_{th}^{\max} \\ 1, & \text{if} \quad K_{th}(X) \le K_{th}^{\min} \end{cases}$$
 (3)

$$\mu_{K_{ec}}(X) = \begin{cases} 0, & if \quad K_{ec}(X) > K_{ec}^{\max} \\ \frac{K_{ec}^{\max} - K_{ec}(X)}{K_{ec}^{\max} - K_{ec}^{\min}} & if \quad K_{ec}^{\min} < K_{ec}(X) \le K_{ec}^{\max} \\ 1, & if \quad K_{ec}(X) \le K_{ec}^{\min} \end{cases}$$
(4)

where matrix table [T] is defined as:

$$[T] = \begin{pmatrix} K_{th}^{\min}(X) = 0.861 & K_{th}^{\max}(X) = 0.931 \\ K_{ec}^{\max}(X) = 0.572 \frac{US\$}{h} & K_{ec}^{\min}(X) = 0.188 \frac{US\$}{h} \end{pmatrix}.$$
 (5)

Fig. 6 shows a Pareto set evaluated for conditions presented by (5), with economic criterion values for 4% per year of interest rate, as viewed in Table 2.

For the conditions related, thermodynamic criterion and economic criterion values meet themselves near to exergetic efficiency ($K_{\rm th}$) of 0.89 for 4 kWh of electrical power generated and operation cost ($K_{\rm ec}$) of 0.375 US\$/h for 20 kg/h of sewage flow mass, which show that these conditions are the best ones for this system. It is because the SWWTP had been design throughout thermoeconomic criterion applied to it.

4. Conclusions

(1)

These simulations can confirm that the modelling proposed is representative for the small waste water treatment plant at UNESP-Guaratingueta. Conditions of constant sewage flow are compared to multi-period variation of sewage flow. This comparison showed that a fuzzy set control is a good way to maintain small waste water treatment plant producing the best amount of its products, including biogas and electrical power to its energy self-sufficiency, with a positive influence in heat exchangers warmth. The exergetic production cost also had a good performance in these simulations, turning around 0.20–0.65 US\$/h to a biogas flow of 1.47 kg/s.

Results deal to previous system optimisation that was a physical optimisation through a thermoeconomic analysis. Then, Pareto set for this one was validated by the previously system optimisation and had confirmed that it is working with better configuration for E_P =4 kWh and \dot{m}_s =20 kg/h.




Fig. 6. Pareto set.

Acknowledgements

The author thanks to Prof. Dr. Victor A. Mazur and Prof. Dr. John E. Dennis, Jr. by your help and paid attention, also for Prof. Dr. Yi Cao by your MATLAB code for Pareto set solution available at Mathworks site.

References

- [1] Lamas WQ Thermoeconomic analysis of a small wastewater treatment station with energetic self-sufficiency. PhD dissertation, Sao Paulo State University, Guaratingueta, 2007. [In Portuguese].
- [2] Lamas WO, Silveira JL, Giacaglia GEO. A small wastewater treatment station built with PVC and associated to biogas power generator. Thermal Engineering 2008;7(2):15–20.
- [3] Lamas WQ, Silveira JL, Giacaglia GEO, Reis LOM. Development of a methodology for cost determination of wastewater treatment based on functional diagram. Applied Thermal Engineering 2009;29(10):2061–71.
- [4] Lamas WQ, Silveira JL, Giacaglia GEO, Reis LOM. Thermoeconomic analysis applied to an alternative wastewater treatment. Renewable Energy 2010;35(10):2288–96.
- [5] Oliveira RA, Foresti E. The mass balance of upflow anaerobic sludge blanket (UASB) from swine residual waters treatment. Agricultural engineering 2004;24(3):807–20 [In Portuguese].
- [6] Oliveira S. Urban solid residues USR: Agronomy course class notes. UNESP-FCA (Department of Natural Resources), Botucatu 2001;1:1–32 [in Portuguese].
- [7] Jordao EP, Alem Sobrinho P Research and experiments with post-treatment for UASB reactors in Brazil. In: Proceedings of PROSAB/ FINEP Report, Sao Carlos; 2004. [in Portuguese].
- [8] Guardabassi P, Pires RG. Electric power self-generation in residential condominiums using waste biogas and natural gas. In: Ferrer JTV, editor. Biogas: Brazilian Projects and Researches. SMA; 2006 [in Portuguese].
- [9] Martins OS, Guardabassi P, Costa DF. Electric power generation from biogas produced in waste water treatment: pilot-project on Barueri WWTS. In: Ferrer JTV, editor. Biogas: Brazilian Projects and Researches. SMA; 2006 [in Portuguese].
- [10] Silveira JL, Balestieri JAP, Almeida RA, Santos AHM, . Thermoeconomic analysis: a criterion for the selection of cogeneration systems. In: Proceedings of International Mechanical Engineering Congress and Exposition— ASME Symposium on Thermodynamics and Design, Analysis and Improvement of Energy Systems, Atlanta, 1996; 36: 240–53.
- [11] Silveira JL A contribution for Thermoeconomic Modelling: Energy Systems Operation and Design Optimisation. PhD dissertation, Sao Paulo State University, Guaratingueta, 1998. [in Portuguese].

- [12] Silveira JL, Tuna CE. Thermoeconomic analysis method for optimisation of combined heat and power system. Part I. Progress in Energy and Combustion 2004;29:479–85.
- [13] Silveira JL, Tuna CE. Thermoeconomic analysis method for optimisation of combined heat and power system. Part II. Prog Energ Combust 2004;30: 673–8.
- [14] Silveira JL, Tuna CE, Lamas WQ, Villela IAC. A contribution for thermoeconomic modelling: A methodology proposal. Applied Thermal Engineering 2010;30(13):1734–40.
- [15] Silveira JL, Lamas WQ, Tuna CE, Villela IAC, Miro LS. Ecological efficiency and thermoeconomic analysis of a cogeneration system at a hospital. Renewable and Sustainable Energy Reviews 2012;16(5):2894–906.
- [16] El-Sayed YM, Evans RB. Thermoeconomics and the design of heat systems. Journal of Engineering for Power-Transactions of the ASME 1970;92(1): 27–25
- [17] Evans RB. Thermoeconomic isolation and energy analysis. Energy 1980;5(8–9): 804–21.
- [18] Frangopoulos CA. Thermoeconomic functional analysis and optimisation. Energy 1987:12(7):563-71.
- [19] Valero A, Lozano MA, Serra L, Tsatsaronis G, Pisa J, Frangopoulos CA, et al. CGAM problem: Definition and conventional solution. Energy 1994;19(3): 279–86.
- [20] Tsatsaronis G, Pisa J. Exergoeconomic evaluation and optimisation of energy systems — application to the CGAM problem. Energy 1994;19(3):287–321.
- [21] Frangopoulos CA. Application of the thermoeconomic functional approach to the CGAM problem. Energy 1994;19(3):323–42.
- [22] von Spakovsky MR. Application of engineering functional analysis to the analysis and optimisation of the CGAM problem. Energy 1994;19(3):343–64.
- [23] Valero A, Lozano MA, Serra L, Torres C. Application of the exergetic cost theory to the CGAM problem. Energy 1994;19(3):365–81.
- [24] Frangopoulos CA, Caralis YC. A method for taking into account environmental impacts in the economic evaluation of energy systems. Energy Conversion and Management 1997;38(15–17):1751–63.
- [25] Curti V, von Spakovsky MR, Favrat D. An environomic approach for the modelling and optimisation of a district heating network based on centralized and decentralized heat pumps, cogeneration and/or gas furnace. Part I: methodology. International Journal of Thermal Sciences 2000;39(7):721–30.
- [26] Curti V, Favrat D, von Spakovsky MR. An environomic approach for the modelling and optimisation of a district heating network based on centralized and decentralized heat pumps, cogeneration and/or gas furnace. Part II: application. International Journal of Thermal Sciences 2000;39(7):731-41.
- [27] Frangopoulos CA, Dimopoulos GG. Effect of reliability considerations on the optimal synthesis, design and operation of a cogeneration system. Energy 2004;29(3):309–29.
- [28] Lazzaretto A, Tsatsaronis G. SPECO: a systematic and general methodology for calculating efficiencies and costs in thermal systems. Energy 2006;31(8–9): 1257–89.

- [29] Verda V. Accuracy level in thermoeconomic diagnosis of energy systems. Energy 2006;31(15):3248-60.
- [30] Grekas DN, Frangopoulos CA. Automatic synthesis of mathematical models using graph theory for optimisation of thermal energy systems. Energy Conversion and Management 2007;48(11):2818–26.
- [31] Dimopoulos GG, Kougioufas AV, Frangopoulos CA. Synthesis, design and operation optimisation of a marine energy system. Energy 2008;33(2):180–8.
- [32] Granovskii M, Dincer I, Rosen MA. Exergy and industrial ecology: an application to an integrated energy system. International Journal of Energy 2008;5:52-63.
- [33] Rosen MA. Allocating carbon dioxide emissions from cogeneration systems: descriptions of selected output-based methods. Journal of Cleaner Production 2008;16(2):171-7.
- [34] Lazzaretto A. A critical comparison between thermoeconomic and energy analyses algebra. Energy 2009;34(12):2196–205.
- [35] Balli O, Aras H, Hepbasli A. Thermodynamic and thermoeconomic analyses of a trigeneration (TRIGEN) system with a gas-diesel engine: Part I – methodology. Energy Conversion and Management 2010;51(11):2252–9.
- [36] Kim DJ. A new thermoeconomic methodology for energy systems. Energy 2010;35(1):410–22.
- [37] Pacheco-Ibarra JJ, Rangel-Hernandez VH, Zaleta-Aguilar A, Valero A. Hybrid fuel impact reconciliation method: an integral tool for thermoeconomic diagnosis. Energy 2010;35(5):2079–87.
- [38] Piacentino A, Cardona E. Scope-oriented thermoeconomic analysis of energy systems. Part I: looking for a non-postulated cost accounting for the dissipative devices of a vapour compression chiller. Is it feasible? Applied Energy 2010;87(3):943–56.
- [39] El-Sayed YM, Aplenc AJ. Application of the thermoeconomic approach to the analysis an optimisation of vapor-compression desalting system. Journal of Engineering for Power-Transactions of the ASME 1970;92(1):17–26.
- [40] Manolas DA, Frangopoulos CA, Gialamas TP, Tsahalis DT. Operation optimisation of an industrial cogeneration system by a genetic algorithm. Energy Conversion and Management 1997;38(15–17):1625–36.
- [41] Sieniutycz S, von Spakovsky MR. Finite time generalization of thermal exergy. Energy Conversion and Management 1998;39(14):1423-47.
- [42] Krause A, Tsatsaronis G, Sauthoff M. On the cost optimisation of a district heating facility using a steam-injected gas turbine cycle. Energy Conversion and Management 1999;40(15–16):1617–26.
- [43] Uche J, Serra L, Valero A. Thermoeconomic optimisation of a dual-purpose power and desalination plant. Desalination 2001;136(1–3):147–58.
- [44] Cziesla F, Tsatsaronis G. Iterative exergoeconomic evaluation and improvement of thermal power plants using fuzzy inference systems. Energy Conversion and Management 2002;43(9–12):1537–48.
- [45] Cziesla F, Tsatsaronis G, Gao Z. Avoidable thermodynamic inefficiencies and costs in an externally fired combined cycle power plant. Energy 2006;31(10–11): 1472–89.
- [46] Frangopoulos CA, Nakos LG. Development of a model for thermoeconomic design and operation optimisation of a PEM fuel cell system. Energy 2006;31(10-11):1501-19.
- [47] Zhang C, Chen S, Zheng C, Lou X. Thermoeconomic diagnosis of a coal fired power plant. Energy Conversion and Management 2007;48(2):405–19.
- [48] Tsatsaronis G, Kapanke K, Blanco-Marigorta AM. Exergoeconomic estimates for a novel zero-emission process generating hydrogen and electric power. Energy 2008;33(2):321–30.
- [49] Piacentino A, Cardona E. Scope oriented thermoeconomic analysis of energy systems. Part II: formation structure of optimality for robust design. Applied Energy 2010;87(3):957–70.
- [50] Seyyedi SM, Ajam H, Farahat S. A new approach for optimisation of thermal power plant based on the exergoeconomic analysis and structural optimisation method: Application to the CGAM problem. Energy Conversion and Management 2010;51(11):2202–11.
- [51] Uson S, Valero A. Thermoeconomic diagnosis for improving the operation of energy intensive systems: Comparison of methods. Applied Energy 2011;88(3):699–711.
- [52] Agudelo A, Valero A, Torres C. Allocation of waste cost in thermoeconomic analysis. Energy 2012;45(1):634–43.
- [53] Verda V, Baccino G. Thermoeconomic approach for the analysis of control system of energy plants. Energy 2012;41(1):38–47.
- [54] Tsatsaronis G, Moran MJ. Exergy-aided cost minimization. Energy Conversion and Management 1997;38(15–17):1535–42.
- [55] Arena AP, Borchiellini R. Application of different productive structures for thermoeconomic diagnosis of a combined cycle power plant. International Journal of Thermal Sciences 1999;38(7):601–12.
- [56] Erlach B, Serra L, Valero A. Structural theory as standard for thermoeconomics. Energy Conversion and Management 1999;40(15–16):1627–49.
- [57] Traverso A, Massardo AF. Thermoeconomic analysis of mixed gas-steam cycles. Applied Thermal Engineering 2002;22(1):1–21.
- [58] Tsatsaronis G, Park M-H. On avoidable and unavoidable exergy destructions and investment costs in thermal systems. Energy Conversion and Management 2002;43(9–12):1259–70.
- [59] Villela IAC, Silveira JL. Thermoeconomics analysis applied in cold water production system using biogas combustion. Applied Thermal Engineering 2005;25(5-6):1141-52.

- [60] Lazzaretto A, Toffolo A, Reini M, Taccani R, Zaleta-Aguilar A, Rangel-Hernandez V, et al. Four approaches compared on the TADEUS (thermo-economic approach to the diagnosis of energy utility systems) test case. Energy 2006;31(10–11):1586–613.
- [61] Paulus DM, Tsatsaronis G. Auxiliary equations for the determination of specific exergy revenues. Energy 2006;31(15):3235–47.
- [62] Tsatsaronis G. Definitions and nomenclature in exergy analysis and exergoeconomics. Energy 2007;32(4):249–53.
- [63] Franzoni A, Magistri L, Traverso A, Massardo AF. Thermoeconomic analysis of pressurized hybrid SOFC systems with CO2 separation. Energy 2008;33(2): 311–320.
- [64] Balli O, Aras H, Hepbasli A. Thermodynamic and thermoeconomic analyses of a trigeneration (TRIGEN) system with a gas-diesel engine: Part II – An application. Energy Conversion and Management 2010;51(11):2260-71.
- [65] Cafaro S, Napoli L, Traverso A, Massardo AF. Monitoring of the thermoeconomic performance in an actual combined cycle power plant bottoming cycle. Energy 2010;35(2):902–10.
- [66] Querol E, Gonzalez-Regueral B, Ramos A, Perez-Benedito JL. Novel application for exergy and thermoeconomic analysis of processes simulated with Aspen Plus®. Energy 2011;36(2):964–74.
- [67] Rovira A, Sanchez C, Munoz M, Valdes M, Duran MD. Thermoeconomic optimisation of heat recovery steam generators of combined cycle gas turbine power plants considering off-design operation. Energy Conversion and Management 2011;52(4):1840–9.
- [68] Campos-Celador A, Perez-Iribarren E, Sala JM, Portillo-Valdes LA. Thermoeconomic analysis of a micro-CHP installation in a tertiary sector building through dynamic simulation. Energy 2012;45(1):228–36.
- [69] Xiong J, Zhao H, Zhang C, Zheng C, Luh PB. Thermoeconomic operation optimisation of a coal-fired power plant. Energy 2012;42(1):486–96.
- [70] Xiong J, Zhao H, Zheng C. Thermoeconomic cost analysis of a 600 MWe oxy-combustion pulverized-coal-fired power plant. International Journal of Greenhouse Gas Control 2012:9:469-83.
- [71] Korbahti BK, Aktas N, Tanyolac A. Optimisation of electrochemical treatment of industrial paint wastewater with response surface methodology. Journal of Hazardous Materials 2007;148(1–2):83–90.
- [72] Oliveira SC, von Sperling M. Reliability analysis of wastewater treatment plants. Water Research 2008;42(4–5):1182–94.
- [73] Zupancic GD, Ros M. Aerobic and two-stage anaerobic-aerobic sludge digestion with pure oxygen and air aeration. Bioresource Technology 2008;99(1): 100–109.
- [74] Mazur VA. Fuzzy thermoeconomic optimisation. Int J Exerg 2005;2(1):1-13.
- [75] Mazur VA. Fuzzy thermoeconomic optimisation of energy-transforming systems. Applied Energy 2007;84(7–8):749–62.
- [76] Toffolo A, Lazzaretto A. Evolutionary algorithms for multi-objective energetic and economic optimisation in thermal system design. Energy 2002;27(6): 549–567.
- [77] Babaie M, Sayyaadi H, Farmani MR Multi-objective particle swarm optimisation and fuzzy decision making in a benchmark cogeneration system. In: Proceedings of IEEE International Conference on Information Engineering and Computer Science 2009, 19–20. 2009, Wuhan, China.
- [78] Sayyaadi H. Multi-objective approach in thermoenvironomic optimisation of a benchmark cogeneration system. Applied Energy 2009;86(6):867–79.
- [79] Hammache A, Benali M, Aube F. Multi-objective self-adaptive algorithm for highly constrained problems: novel method and applications. Applied Energy 2010;87(8):2467–78.
- [80] Sayyaadi H, Babaie M, Farmani MR. Implementing of the multi-objective particle swarm optimizer and fuzzy decision-maker in exergetic, exergoeconomic and environmental optimisation of a benchmark cogeneration system. Energy 2011;36(8):4777–89.
- [81] Dipama J, Teyssedou A, Aube F, Lizon-A-Lugrin L. A grid based multi-objective evolutionary algorithm for the optimisation of power plants. Applied Thermal Engineering 2010;30(8–9):807–16.
- [82] Das I, Dennis Jr. JE. Normal-boundary intersection: a new method for generating the Pareto surface in nonlinear multicriteria optimisation problems, TR96-19. Houston, TX: Rice University; 1996.
- [83] Das I, Dennis Jr. JE. A closer look at drawbacks of minimizing weighted sums of objectives for Pareto set generation in multicriteria optimisation problems, TR96-36. Houston, TX: Rice University; 1996.
- [84] Das I Nonlinear Multicriteria Optimisation and Robust Optimality. PhD thesis, TR97-6, Rice University, Houston, TX, 1997.
- [85] Das I, Dennis Jr. JE. Normal-boundary intersection: a new method for generating the Pareto surface in nonlinear multicriteria optimisation problems. SIAM Journal on Optimization 1998;8(3):631–57.
- [86] Lamas WQ Fuzzy logic application to multi-period optimisation of a SWWTP performance. In: Proceedings of VI Congress of Logic Applied to Technology, 2007, Santos. Frontiers in Artificial Intelligence and Applications. Amsterdam: IOS Press. p. 1–15. [in Portuguese].
- [87] Wylen G, Sonntag R, Borgnakke C. Fundamentals of classical thermodynamics. 6th ed. New York: John Wiley & Sons; 2003.
- [88] Beduschi LC, Lopes LR, Benincasa M, Ortolani AF, Lucas Jr. J. Economic feasibility of methane digestors. Engineering Agriculture Botucatu 1983;6(2): 31–36 [in Portuguese].